

SECTION 05000 - METALS

PART 1 - GENERAL

1.1 SCOPE OF SECTION:

This section contains the requirements relating to light gage metal framing, cold-formed metal framing, and metal fabrications (except as used with roofing).

1.2 LIGHT GAGE METAL FRAMING:

A. INTERIOR WALLS:

1. Metal framing shall be used for interior wall partitions. The use of wood framing is not acceptable.
2. Steel studs shall be 22 gauge or heavier. The use of 25 gauge wall studs is prohibited.
3. All metal stud framing shall be spaced a maximum of 16" on center.

1.3 COLD-FORMED METAL FRAMING:

A. EXTERIOR WALLS: (Refer also to Section 04000)

1. The use of structural cold-formed metal-framed exterior backup walls is permitted and shall meet criteria as outlined in the most current publication of the American Brick Institute.

1.4 METAL FABRICATIONS:

- ##### A. STAIR NOSINGS: All stair treads shall have a nosing with minimum 4" wide abrasive non-slip surface, and heavy-duty aluminum frame.

END OF SECTION