

SECTION 13038 – COLD STORAGE ROOMS and BUILDINGS

1.1 SCOPE OF SECTION:

This section contains the requirements for Walk-In Cold Room equipment and installation including associated appurtenances necessary for full operation.

1.2 WALK-IN COLD ROOMS:

A. Refrigeration Systems:

1. Specify water- cooled condensers only.
2. Connect supply and return piping to the building chilled water supply and return system.
3. Provide emergency back-up connection to the domestic water system, utilizing the appropriate combination of valves and double check valves for backflow prevention.

END OF SECTION